

1144

NB: 2768

FORM U-1 MANUFACTURERS' DATA REPORT FOR UNFIRED PRESSURE VESSELS

As required by the Provisions of the ASME Code Rules and the National Board

1. Manufactured by W. West Industries, Inc. HOUSTON, TEXAS
2. Manufactured for THE RANSOME COMPANY P.O. BOX 3047 HOUSTON, TEXAS
3. Type Vert. Kind Jkt'd. Vessel No. H-2478-61-23 Texas Nat'l Bd. No. 2768 Yr. Built 1962

Items 4-9 incl. to be completed for single wall vessels (such as tank, jacket or jacketed vessels, or shells of Heat Exchangers)

4. SHELL Material T.S. thickness in Corrosion Allowance in Diam. in Length ft. in.
5. SEAMS: Long (Welded, Dbl., Single, Lap, Butt) SR (Yes or No) X.R. (Spot or Complete) Sectioned (Yes or No) Efficiency %
6. HEADS (a) Material T.S. (b) Material T.S. Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex angle Hemispherical Radius Flat Diameter Side to Pressure (Convex or Concave)

If riveted describe seams fully on reverse side of form

7. STAYBOLTS (Material) If hollow Attachment Pitch (Horizontal) (Vertical) Diam. (Nominal)
8. JACKET CLOSURE: (Describe as open & weld bar, etc. If bar give dimensions, if bolted, describe in sketch)
9. Constructed for (Int.) (Ext.) pressure of 390 psi Max Temp 650 °F Subzero -320 °F Hydrostatic Test 800 psi

Items 10 and 11 to be completed for tube sections.

10. TUBE SHEETS: Stationary Material (Kind & Spec. No.) Diam. in Thickness in Attachment (Welded, Bolted)
Floating Material (Kind & Spec. No.) Diam. in Thickness in Attachment
11. TUBES: Material O.D. in Thickness inches of gage Number Type (Straight or U)

Items 12-15 incl. to be completed for inner chambers of jacketed vessels, or chambers of heat exchangers.

12. SHELL: Material T.S. 95,000 Thickness 7/32 Corrosion Allowance 0 in Diam 3 (10 1/4) Length - ft. in.
13. SEAMS: Long (Welded, Dbl., Single, Lap, Butt) SR (Yes or No) X.R. (Spot or Complete) Sectioned (Yes or No) Efficiency %
14. HEADS (a) Material T.S. (b) Material T.S. (c) Material T.S. Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex angle Hemispherical Radius Flat Diameter Side to Pressure (Convex or Concave)
15. Constructed for (Int.) (Ext.) pressure of 15 psi Max Temp 650 °F Subzero -320 °F Hydrostatic Test 800 psi

If riveted describe seams fully on reverse side of form

Items below to be completed for all Vessels where applicable.

16. SAFETY VALVE OUTLETS: Number Size
17. NOZZLES: Purpose (Inlet, Outlet, Drain) Number Diam. or Size Type Material Thickness Reinforcement Material How Attached
18. INSPECTION OPENINGS: Manholes, No. Size Location Handholes, No. Size Location Threaded, No. Size Location
19. SUPPORTS: Skirt (Yes or No) Legs (Number) Other Three (3) Other Attached Wld. to O.S. Shell.
20. REMARKS: LIQUID OXYGEN SPHERE

17. NOZZLES:								
Purpose (Inlet, Outlet, Drain)	Number	Diam. or Size	Type	Material	Thickness	Reinforcement Material	How Attached	
Fill & Outlet	One	3/4" Sch. 10S Pipe		SA-213T304SS	.083"	SA-213T304SS	Wld'd	
Vent & TopGage	do	do	do	do	.083"	do	do	
Top Fill	do	do	do	do	.083"	do	do	
Full Conn.	do	1/4"	do	do	.065"	do	do	
Vaporizer Feed	One	1/2" Sch. 10S Pipe		SA-213T304SS	.083"	SA-213T304SS	Wld'd	

We certify that the statements made in this report are correct and that all details of material, construction, and workmanship of this unfired pressure vessel conform to the ASME Code for Unfired Pressure Vessels.

Date AUG 14 1962 19      Signed Wyatt Industries, Inc. By Wendell Grant  
(Manufacturer)

Certificate of Authorization Expires December 31, 1965

### CERTIFICATE OF SHOP INSPECTION

Inspection Agency's Serial No. 17422

VESSEL MADE BY Wyatt Industries, Inc. at HOUSTON, TEXAS

I, the undersigned, holding a Certificate of Competency as an Inspector of Boilers and Unfired Pressure Vessels in THE STATE OF TEXAS and employed by HARTFORD STEAM BOILER INSPECTION & INS. CO., CONN.

inspected internally and externally, the vessel described in this report on AUG 14 1962, 19     , and certify that the statements made in this report are correct corresponding with mill test reports of materials furnished by the builder, and measurements made of the vessel and that this vessel is constructed in accordance with the ASME Code for Unfired Pressure Vessels.

Date AUG 14 1962 19           NATIONAL BOARD # 1195  
     Commissions TEXAS STATE COMMISSION # 25  
Inspector's Signature State or Nat'l Bd. & Number

### CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a Certificate of Competency as an Inspector of Boilers and Unfired Pressure Vessels in THE STATE OF      and employed by      of     

have compared the statements in this manufacturer's data report with the completed vessel, and certify that parts referred to as data items      were completed in the field in accordance with the requirements of the

ASME Code for Unfired Pressure Vessels. The completed vessel was inspected and subjected to a hydrostatic test of      psi.

Date      19           Commissions       
Inspector's Signature State or Nat'l Bd. & Number

\* MATERIAL: SA-300-5BT Cl.4 SA-353 Gr."B" F.B. (9% Nickel)